



PLAN REVIEW SHEET

Date: 01.16.09
Petitioner: Morrison Place, LLC
Petition: 2009-022

Staff Contact: David McDonald
Telephone: 704-336-6900
Fax: 704-432-1277
Email: dmcdonald@ci.charlotte.nc.us
Attachments: n/a

I. SUMMARY REMARKS:

FIRST SUBMITTAL

CATS acknowledges receipt of the site plan and requests that petitioner provide a concrete waiting pad along Sharon Road, in the vicinity of the existing bus (pole) stop, adjacent to Petitioner's Tract 3. Concrete pad should conform to Development Standard 60.03A or 60.04A (see attachments). Petitioner should contact William (Budd) Early at CATS to finalize the selection of the Development Standard and to finalize location details (704.432.2557).

Should you require additional information, please advise.