



Charlotte Department of Transportation

Memorandum

Date: May 22, 2009

To: Tom Drake & Tammie Keplinger
Charlotte-Mecklenburg Planning Department

From: Michael A. Davis, PE *Mike Davis*
Development Services Division

Subject: Rezoning Petition 09-048: Located between East 7th street and
Weddington Avenue

Consistency with Transportation Action Plan (TAP): The two goals of the TAP that most directly affected the staff's review of this petition define the integration of land use and transportation, and the provision of transportation choices.

- Goal 1 of the TAP relies on implementation of the Centers, Corridors and Wedges land use strategy. This project site is located in a Corridor. Such areas should include a dense and interconnected street network. Specific comments are provided below to link proposed changes in land use with improved transportation network.
- Goal 2 of the TAP describes various connectivity and design features that are important for motorists, pedestrians and bicyclists. Specific comments are provided below to apply best practices for multimodal transportation.

Vehicle Trip Generation

This site could generate approximately 900 trips per day as currently zoned. Under the proposed zoning the site could generate approximately 2500 trips per day. This will have a minor impact on the surrounding thoroughfare system.

Since access is proposed to an NCDOT-maintained roadway, they may require a TIS as part of their driveway permit approval process. They may have additional or different requirements for their approval than what is identified in this rezoning process. The petitioner is recommended to meet with NCDOT early in the development process to identify any issues that they may have.

CDOT requests the following changes to the rezoning plan:

1. We request a note be added to the plan stating that the Private Drive connection between 7th street and Weddington Avenue will remain open 24 hours a day, 7 days a week, and will not be gated.

CDOT is aware that the following items may be required during the NCDOT's driveway review process:

1. NCDOT currently maintains 7th Street and may require left-turn lanes at the entrances into the proposed development along 7th Street. CDOT will be working with NCDOT in order to preserve the curblines in their current locations.

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. Adequate sight triangles must be reserved at the proposed street entrances. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrances. Such items should be identified on the site plan.
2. The proposed driveway connections to 7th Street and Weddington Avenue will require driveway permits to be submitted to CDOT and the North Carolina Department of Transportation for review and approval. The exact driveway locations and type/width of the driveways will be determined by CDOT during the driveway permit process. The locations of the driveways shown on the site plan are subject to change in order to align with driveways on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
3. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
4. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

If we can be of further assistance, please advise.

- c: R. H. Grochoske (via email)
J. Shapard – Review Engineer (via email)
B. D. Horton (via email)
A. Christenbury (via email)
E. D. McDonald (via email)
T. Votaw (via email)
Rezoning File