



MECKLENBURG COUNTY
Land Use and Environmental Services Agency

August 19, 2009

Mr. Michael Cataldo
Charlotte-Mecklenburg Planning Commission
600 East Fourth Street
Charlotte, North Carolina 28202

Re: Rezoning Petition 2009-068
Approximately 13.98 acres located on the south side of Mallard Creek Road
across from Mason Drive and beside Penninger Circle

Dear Mr. Cataldo:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

Programs with No Comment at this Time

Solid Waste
Storm Water Services

Recommendations or Ordinance Requirement Reminders

Air Quality

Development of this site may require submission of an asbestos Notification of Demolition and Renovation due to possible demolition or relocation of an existing structure or renovation of a load-bearing wall in an existing structure. This notification is required in accordance with the Mecklenburg County Air Pollution Control Ordinance (MCAPCO) Regulation 2.1110 - Subparagraph (a) - "National Emission Standards for Hazardous Air Pollutants". A letter of notification and the required forms will be mailed directly to the parcel owner.

Groundwater & Wastewater Services

Review of Groundwater & Wastewater Service data and the age of homes indicate that parcels 047-331-04, 047-331-05, and 047-331-07 were served by private on-site water supply wells and individual on-site wastewater systems.

Groundwater & Wastewater Services request the following statements be added to the notes of the site plan:

Existing water supply wells shall be cordoned off to protect from damage or abandoned per the Mecklenburg County Groundwater Well Regulations prior to any demolition or grading activity.

Existing septic tanks shall be located, pumped by a licensed waste hauler to remove residual contents, crushed and backfilled prior to any demolition or grading activity.

Please contact the staff members who conducted the reviews if you have any questions.

The reviews were conducted by, Leslie Rhodes

(Leslie.Rhodes@mecklenburgcountync.gov) with MCAQ, Jack Stutts

(Jack.Stutts@mecklenburgcountync.gov) with GWS, Joe Hack

(Joe.Hack@mecklenburgcountync.gov) with MCSW, Bill Tingle

(Bill.Tingle@mecklenburgcountync.gov) with MCSWS, and Rusty Rozzelle

(Rusty.Rozzelle@mecklenburgcountync.gov) with the MCWQ.

Respectfully,

Heidi Pruess, Environmental Policy Administrator

Heidi.Pruess@mecklenburgcountync.gov