



**CHARLOTTE FIRE DEPARTMENT**  
**700 North Tryon Street**  
**Post Office Box 31097 Charlotte, N.C. 28231-1097**

**Plan Review Sheet**

**Petitioner: York Development Group**  
**Petition Number: 2009-080**  
**Fire Plans Examiner: R.Turner**  
**Telephone: 704-336-3814**

**Review: 2**  
**Date Received: 11/19/09**  
**Date Reviewed: 11/19/09**  
**Fax: 704-336-3839**

**E-Mail: [turner@ci.charlotte.nc.us](mailto:turner@ci.charlotte.nc.us)**

**Remarks :**

- 1. An unobstructed width of 20ft required for all access drives including both sides of a median.**