



November 30, 2009

Attention: Michael Cataldo
Petition #: 2010-015

Proximity to CMUD Water:

Existing 12" Water Main is accessible southeast of the Site along N. Tryon Street.

Existing 12" Water Main is accessible southwest of Tax Parcel #07802401 along W. Sixth Street.

Existing 8" Water Main is accessible northeast of Tax Parcel #07802401 along W. Seventh Street.

Existing 6" Water Main is accessible northeast of Tax Parcel #07802507 along W. Seventh Street.

Existing 12" Water Main is accessible southwest of Tax Parcel #07802506 along W. Sixth Street located from intersection of N. Church Street traveling approximately 65 Linear Feet northwest. The Water Main then reduces to a 6" line southwest of Tax Parcel #07802506 along W. Sixth Street and continues northwest.

Existing 12" Water Main is accessible through the Site along N. Church Street from intersection at W. Sixth Street traveling northeast approximately 250 Linear Feet. The Water Main is then reduced to a 6" line from that point to the intersection at W. Seventh Street.

Proximity to CMUD Sewer:

Existing 8" Sewer is accessible northeast of Tax Parcel #07802401 in W. Seventh Street.

Existing 12" Sewer is accessible southeast of site in N. Tryon Street.

Existing 8" Sewer is accessible southwest of site in W. Sixth Street fronting Parcel #07802401 and Parcel #07802506.

Existing 8" Sewer in N. Church Street from intersection of E. Sixth Street traveling northeast approximately 35 Linear Feet.

Tax Parcel #07802507 does not appear to have access to sewer. However, an extension may be applied for through the CMUD Street Main Extension Program to serve the Parcel.