



**CHARLOTTE FIRE DEPARTMENT**  
**700 North Tryon Street**  
**Post Office Box 31097 Charlotte, N.C. 28231-1097**

**Plan Review Sheet**

**Petitioner: City of Charlotte**  
**Petition Number: 2010-015**  
**Fire Plans Examiner: R. Turner**  
**Telephone: 704-336-3814**

**Review: 1**  
**Date Received: 12-7-09**  
**Date Reviewed: 12-10-09**  
**Fax: 704-336-3839**

**E-Mail : [turner@ci.charlotte.nc.us](mailto:turner@ci.charlotte.nc.us)**

**Remarks :**

**None**

Comments by staff will be based on an initial review of conceptual and/or preliminary drawings and project information, and therefore are not to be considered as binding. Submittal of additional information, or a later more detailed evaluation of the plans, including an evaluation made by a field inspector after building permits have been issued, may result in a change in interpretation by the Department as to the application of the NC State Fire Code and Ordinances to the project.