



PLAN REVIEW SHEET

Date: 5/16/2011

Petition: 2011-046


Staff Contact: Tina Votaw
Telephone: 704-432-3013

Email: tvotaw@charlottenc.gov
Attachments: Pad 60.04B

I. SUMMARY REMARKS:

CATS requests that Petitioner provide a bus waiting pad as shown on the attached standard, Pad 60.04B. Please contact Tina Votaw of CATS at 704.432.3013 or Budd Early of CATS at 704.432.2557 for further information on location of the request pad or other related information.

Thank you.



LEGEND

- NEW CONCRETE WAITING PAD 6" THICK
- TRASH RECEPTACLE
- SIGN
- ADA SPACE
- 5X15 STRUCTURE
- BICYCLE RIB RACK IF REQUIRED

NOTES:

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. 2' MINIMUM PLANTING STRIP. 4' PLANTING STRIP IS TYPICAL.

REVISIONS		
NO.	DATE	DESCRIPTION

APPROVED DATE _____

**CHARLOTTE-MECKLENBURG
LAND DEVELOPMENT
STANDARDS**



**WAITING PAD WITH 5'X15' BOX SHELTER
WITHOUT PLANTING STRIP**

STD. NO.	REV.
60.04B	