



2012-001 Tyler Foster, Mercury NoDa, LLC

Reviewer: Mavis Gant

Date: December 22, 2011

Comments:

Site plan is missing the necessary Solid Waste notes for multifamily usage. Plans must specify garbage container type (dumpster, compactor), recycling space allowed, or if site proposes use of a private hauler.

Other issues:

Trucks cannot drive into deck to service. Garbage dumpsters and recycling carts must be rolled out to the street in order to be serviced if serviced under the City multifamily contract.