



MECKLENBURG COUNTY
Land Use and Environmental Services Agency

December 15, 2011

Mr. Michael Cataldo
Charlotte-Mecklenburg Planning Commission
600 East Fourth Street
Charlotte, North Carolina 28202

Re: Rezoning Petition 2012-006

Approximately 5.75 acres located on the north side of Millerton Avenue near the intersection of West Morehead Street and Julian Price Place

Dear Mr. Cataldo,

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

Programs with No Comment at this Time

Solid Waste
Groundwater & Wastewater Services

Recommendations and/or Ordinance Requirement Reminders

Air Quality

Development of this site may require submission of an asbestos Notification of Demolition and Renovation due to possible demolition or relocation of an existing structure or renovation of a load-bearing wall in an existing structure. This notification is required in accordance with the Mecklenburg County Air Pollution Control Ordinance (MCAPCO) Regulation 2.1110 - Subparagraph (a) - "National Emission Standards for Hazardous Air Pollutants". A letter of notification and the required forms will be mailed directly to the parcel owner.

Storm Water Services

The requirements of the post-construction storm water ordinance for the City of Charlotte should be applied to the proposed rezoning. More detailed information regarding ordinance requirements is available at the following website:

<http://charmeck.org/stormwater/regulations/Pages/Post-ConstructionStormWaterOrdinances.aspx> and click on City of Charlotte.

PEOPLE • PRIDE • PROGRESS • PARTNERSHIP

700 N. Tryon Street • Suite 205 • Charlotte, NC 28202-2236 • (704) 336-5500 • FAX (704) 336-4391

www.4citizenhelp.com

Impaired Streams:

The property represented in this rezoning drains to surface waters listed on North Carolinas Department of Natural Resources 303(d) list of impaired streams. Irwin Creek is listed for copper, lead, zinc, turbidity, ecological/biological integrity of fish communities, and fecal coliform due to pollution discharges. By properly controlling pollutants both during and after construction you can help restore these surface waters. More information on North Carolina's impaired waters and 303(d) list can be found at <http://portal.ncdenr.org/web/wq/ps/mtu/assessment>.

Please contact the staff members who conducted the reviews if you have any questions.

The reviews were conducted by, Leslie Rhodes

(Leslie.Rhodes@mecklenburgcountync.gov) with MCAQ, Dennis Tyndall

(Dennis.Tyndall@mecklenburgcountync.gov) with GWS, Joe Hack

(Joe.Hack@mecklenburgcountync.gov) with MCSW, Bill Tingle

(Bill.Tingle@mecklenburgcountync.gov) with MCSWS, and Rusty Rozzelle

(Rusty.Rozzelle@mecklenburgcountync.gov) with the MCWQ.

Respectfully,

Heidi Pruess, Environmental Policy Administrator

Heidi.Pruess@mecklenburgcountync.gov