



PLAN REVIEW SHEET

Date: 12/14/2011


Petition: 2012-008

Staff Contact: Tina Votaw
Telephone: 704-432-3013

Email: tvotaw@charlottenc.gov
Attachments: **Waiting Pad Spec. 60.05A**

I. SUMMARY REMARKS:


CATS requests that the Petitioner provide a concrete waiting pad as shown on the attached specification. Please contact Budd Early at CATS (704.432.2557) if there are any questions regarding this request. Thank you.




PLAN VIEW
NTS

LEGEND

NEW CONCRETE WAITING PAD 6" THICK



NEW CONCRETE WAITING PAD 4" THICK




TRASH RECEPTACLE




SIGN



ADA SPACE



5X10 STRUCTURE



BICYCLE RIB RACK IF REQUIRED



NOTES:

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. 2' MINIMUM PLANTING STRIP. 4' PLANTING STRIP IS TYPICAL.

REVISIONS

NO.	DATE	DESCRIPTION

APPROVED DATE _____

**CHARLOTTE-MECKLENBURG
LAND DEVELOPMENT
STANDARDS**



**WAITING PAD WITH 5'X10' CANTILEVER SHELTER
WITH PLANTING STRIP**

STD. NO.	REV.
60.05A	