



PLAN REVIEW SHEET

Date: 12/14/2011

Staff Contact: Tina Votaw

Petition: 2012-010


Telephone: 704-432-3013

Email: tvotaw@charlottenc.gov

Attachments: **Waiting Pad Spec. 60.01A**

I. SUMMARY REMARKS:

CATS requests that the Petitioner provide a concrete waiting pad as shown on the attached specification. Please contact Budd Early at CATS (704.432.2557) if there are any questions regarding this request. Thank you.



LEGEND

TRASH RECEPTACLE



SIGN



ADA SPACE



NEW CONCRETE WAITING PAD 4" THICK



NOTES:

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. 2' MINIMUM PLANTING STRIP. 4' PLANTING STRIP IS TYPICAL.

REVISIONS

NO.	DATE	DESCRIPTION

APPROVED DATE _____

**CHARLOTTE-MECKLENBURG
LAND DEVELOPMENT
STANDARDS**



**WAITING PAD ONLY
WITH PLANTING STRIP**

STD. NO.	REV.
60.01A	