



Charlotte Department of Transportation

Memorandum

Date: March 16, 2012

To: Tammie Keplinger
Charlotte-Mecklenburg Planning Department

From: Michael A. Davis, PE *Mike Davis*
Development Services Division

Subject: Rezoning Petition 12-049: Approximately 34.0 acres located on the west side of Carmel Road between Quail Hollow Road and Bridgewood Lane

CDOT has completed a review of the subject petition in order to ensure consistency with the Transportation Action Plan (TAP). The TAP seeks to ensure that Charlotte's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users. Based on our review of the petition, we offer the following comments.

Vehicle Trip Generation

This site could generate approximately 1500 trips per day as currently zoned. Under the proposed zoning the site could generate approximately 2700 trips per day. This will have a minor impact on the surrounding thoroughfare system.

CDOT requests the following changes to the rezoning plan:

1. We request a 13 foot planting strip along Carmel Road to reserve the space for a future bicycle lane along the site's frontage.

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. Adequate sight triangles must be reserved at the existing/proposed street entrances. Two 35' x 35' sight triangles are required for the entrances to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrances. Such items should be identified on the site plan.
2. The proposed driveway connections to Carmel Road will require a driveway permits to be submitted to CDOT and the North Carolina Department of Transportation for review and approval. The exact driveway location and type/width of the driveway will be determined by CDOT during the driveway permit process. The locations of the driveway shown on the site plan are subject to change in order to align with driveway on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.

Tammie Keplinger

March 16, 2012

Page 2 of 2

3. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
4. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
5. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

If we can be of further assistance, please advise.

FO

c: R. H. Grochoske
B. D. Horton
Rezoning File