



PLAN REVIEW SHEET

Date: 9/14/2012

Staff Contact: Tina Votaw

Petition: 2012-097

Telephone: 704-432-3013

Email: tvotaw@charlottenc.gov

Attachments: N/A

I. SUMMARY REMARKS:

We request that the Petitioner provide a concrete waiting pad at existing bus stop, northbound on Sharon Amity at Delane. The size and specification of the concrete waiting pad at bus stop would be from curb to 9 feet back of curb and be 5 feet in width. Pad must be flush with sidewalk and level within 2% when measured perpendicular to street for compliance with the ADA. The Petitioner should contact me if there are any questions relative to this request. Thank you.