



REZONING MEMORANDUM  
ARBORIST OFFICE

Reviewer: Laura Brewer  
Phone: 704.336.5753  
E-Mail: lbrewer@charlottenc.gov

Date: 1.2.13  
Petition Number: revised 2012-103, 2012-101

COMMENTS:

Pet. 2012-101 The new trees to be planted on Steele Creek Rd will need to be behind the sidewalk unless the planting strip is increased to 8ft. It is also preferred that they be behind the sidewalk due to this being an NCDOT roadway.

Pet. 2012-103 No comments.