



PLAN REVIEW SHEET

Date: 1/20/2012

Staff Contact: Brian Horton

Petition: 2013-006


Telephone: 704-353-0018

Email: bhorton@charlottenc.gov

Attachments: Concrete Pad Spec

I. SUMMARY REMARKS:

We request that the Petitioner provide a concrete waiting pad for planned bus service, northbound on Prosperity Church Road at Ridge Road. The size and specification of the concrete waiting pad at bus stop would be from curb to proposed 6-foot sidewalk and be 5 feet in width. Pad must be flush with sidewalk and level within 2% when measured perpendicular to street for compliance with the ADA. Please see attached standard. Please contact me if there are any questions relative to this request. Thank you.



LEGEND

TRASH RECEPTACLE



SIGN



ADA SPACE



NEW CONCRETE WAITING PAD 4" THICK



NOTES:

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. 2' MINIMUM PLANTING STRIP. 4' PLANTING STRIP IS TYPICAL.

REVISIONS

NO.	DATE	DESCRIPTION

APPROVED DATE _____

**CHARLOTTE-MECKLENBURG
LAND DEVELOPMENT
STANDARDS**



**WAITING PAD ONLY
WITH PLANTING STRIP**

STD. NO.	REV.
60.01A	