



REZONING MEMORANDUM  
ARBORIST OFFICE

Reviewer: Laura Brewer  
Phone: 704.336.5753  
E-Mail: lbrewer@charlottenc.gov

Date: 11/15/12  
Petition Number: 2013-006

COMMENTS: The perimeter trees do not have sufficient space between sidewalks and other hardscape for long term growth. A minimum 8 ft wide planting area is required for Tree Ordinance compliance. Existing trees within the right of way need to be shown, and are protected by Ordinance. Other tree preservation may be required by Urban Forestry.