

FY 2013 January Re-Zoning Petition Review - Jarred Fuller - CMUD

FY 2013 Petition #	Water Availability	Sewer Availability
2013-001	24-inch water main stubbed out onto Dixie River Road from Steele Creek Road	8-inch and 10-inch gravity sewer main passing through site
2013-002	12-inch water main on W. Arrowood Road and a 16-inch water main on Sandy Porter Road	24-inch gravity sewer main running along stream on the northeast side of the site.
2013-003	Text Amendment - No Review	Text Amendment - No Review
2013-005	20-inch water main on W. MLK Blvd, 6-inch water mains on all streets surrounding the site	15-inch gravity sewer main on Mint Street, 8-inch gravity sewer mains on all other streets surrounding the site
2013-006	24-inch water main on Prosperity Church Road and an 18-inch water main on Old Ridge Road.	8-inch gravity sewer on Ridge Road

*This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.