



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2013-017	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	October 3, 2013
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

16-inch water main on Little Rock Road.

8-inch gravity sewer main on Little Rock Road and running through property under review. From the proposed site plan, the proposed building footprint is on top of the existing gravity sewer main. The developer would need to work either relocate the building location, or work with CMUD's donated projects to relocate the sewer main.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.