



PLAN REVIEW SHEET

Date:	12/12/2012	Staff Contact:	Brian Horton
Petition:	2013-020 Durban Development	Telephone:	704-353-0018
		Email:	bhorton@charlottenc.gov
		Attachments:	Concrete Pad Spec

I. SUMMARY REMARKS:

We request that the Petitioner provide a waiting pad along Milton Road between the required new sidewalk and the existing curb within the new planting strip.

The size and specification of the concrete waiting pad at the bus stop would be located between the existing curb and the new 6 foot sidewalk and be 5 feet in width. Pad must be flush with sidewalk and level within 2% when measured perpendicular to street for compliance with the ADA. Below is an image of the standard (CLDSM – 60.01A) waiting pad.

Please contact me if there are any questions relative to this request. Thank you.

