



**PLAN REVIEW SHEET**

<b>Date:</b>	1/14/2013	<b>Staff Contact:</b>	Brian Horton
<b>Petition:</b>	2013-032 The Housing Partnership	<b>Telephone:</b>	704-353-0018
		<b>Email:</b>	bhorton@charlottenc.gov
		<b>Attachments:</b>	Concrete Pad Spec

**I. SUMMARY REMARKS:**

We request that the Petitioner provide a waiting pad for restored bus service along Double Oaks Road.

The size and specification of the concrete waiting pad at the bus stop would be located between the existing curb and the existing sidewalk and be 5 feet in width. Pad must be flush with sidewalk and level within 2% when measured perpendicular to street for compliance with the ADA. Below is an image of the standard (CLDSM – 60.01A) waiting pad.

Please contact me if there are any questions relative to this request. Thank you.

