

FY 2013 March Re-Zoning Petition Review - Jarred Fuller - CMUD

FY 2013 Petition #	Water Availability	Sewer Availability
2013-025	16-inch and 24-inch water mains on Old Concord Road	8-inch gravity sewer main crossing the site
2013-26	Text amendment - No comment	Text amendment - No comment
2013-27	2-inch and 12-inch water mains Euclid Avenue and a 6-inch water main on E. Tremont Avenue	8-inch gravity sewer mains on Euclid Avenue and E. Tremont Avenue
2013-28	6-inch, 12-inch and 54-inch water mains on Morehead Street	8-inch gravity sewer main on Morehead Street
2013-29	Text amendment - No comment	Text amendment - No comment
2013-30	8-inch water main on Ballantyne Commons Parkway	8-inch gravity sewer main on Ballantyne Commons Parkway
2013-31	6-inch water mains on Statesville Avenue and Samuel Street and a 2-inch water main on Newland Road	8-inch gravity sewer mains on Statesville Avenue, Samuel Street and Newland Road and a 33-inch gravity sewer main on the property line bordering Irwin Creek
2013-32	8-inch water mains on Newland and Double Oaks Roads	8-inch gravity sewer main on Double Oaks Road

*This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.