



PLAN REVIEW SHEET

Date: 3/20/2013
Petition: 2013-043
 Novant Health, Inc.

Staff Contact: Brian Horton
Telephone: 704-353-0018
Email: bhorton@charlottenc.gov
Attachments: Concrete Pad Spec

I. SUMMARY REMARKS:

We request that the Petitioner provide a waiting pad for bus service along East 4th Street. The pad may be located beneath the possible future pedestrian bridge near side of the driveway following existing Barnette Place.

The concrete waiting pad would be located between the existing curb and the new sidewalk. Pad must be flush with sidewalk and level within 2% when measured perpendicular to street for compliance with the ADA. Below is an image of the standard (60.01B) detail.

Please contact me if there are any questions relative to this request. Thank you.

