



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2013-058	Review Number:	1
Petition Reviewer:	Jarred Fuller	Date Reviewed:	May 14, 2013
Phone Number:	704-391-5082	Email Address:	jfuller@charlottenc.gov

Comments:

6-inch water main on Capitol Drive and a 12-inch water main on Morris Field Drive

8-inch gravity sewer main on Capitol Drive

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.