



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2013-059	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Jarred Fuller	<b>Date Reviewed:</b>	May 14, 2013
<b>Phone Number:</b>	704-391-5082	<b>Email Address:</b>	jfuller@charlottenc.gov

**Comments:**

8-inch water mains on Hawthorne Lane and Louise Avenue

8-inch gravity sewer main on site

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.