



Date: 8/22/13

To: Zenia Duhaney Charlotte Planning Dept.

From: R.E. Vandergrift
South Division

Subject: 2013-071

The Charlotte-Mecklenburg Police Department request that this site use IESNA standards on lighting for multi family properties and for it's parking lots. The lighting should be installed taking into account the placement of the landscaping. The screening that is proposed will limit the visibility in to the parking lots and create hiding spaces. The police department request that the screening be changed to allow for 75% visibility.

Copies To: