



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2013-075	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	July 8, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

12-inch water main on South Tryon Street.

Gravity Sewer Main present on S Tryon Street..

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.