



Charlotte Department of Transportation

Memorandum

Date: August 26, 2013

To: Tammie Keplinger
Charlotte-Mecklenburg Planning Department

From: Michael A. Davis, PE *Mike Davis*
Development Services Division

Subject: Rezoning Petition 13-086: Approximately 3.6 acres located on the west side of Little Hope Road between Marsh Road and Paddock Circle.

CDOT has completed a review of the subject petition in order to ensure consistency with the Transportation Action Plan (TAP). The TAP seeks to ensure that Charlotte's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users. Based on our review of the petition, we offer the following comments.

Vehicle Trip Generation

This site could generate approximately 150 trips per day as currently zoned. Under the proposed zoning the site could generate approximately 150 trips per day.

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. Adequate sight triangles must be reserved at the proposed street entrance. Two 35' x 35' sight triangles are required for the entrance to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance. Such items should be identified on the site plan.
2. The proposed public street connection to Little Hope Road will require a driveway permit to be submitted to CDOT for review and approval. The exact driveway location and type/width of the driveway will be determined by CDOT during the Subdivision review process. The location of the driveway shown on the site plan is subject to change in order to align with driveways on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
3. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
4. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.

Tammie Keplinger

August 26, 2013

Page 2 of 2

5. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

If we can be of further assistance, please advise.

F. Obregon

cc: S. Correll
Rezoning File