



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

| | | | |
|---------------------------|--------------|-----------------------|--------------------------|
| Petition #: | 2013-088 | Review Number: | 1 |
| Petition Reviewer: | Matt Bedford | Date Reviewed: | October 14, 2013 |
| Phone Number: | 704-391-5163 | Email Address: | mbedford@charlottenc.gov |

Comments:

6-inch water main on Morehead Square Drive, East Palmer Street, and South Tryon Street.

Gravity Sewer main located along Morehead Square Drive, runs through parcel under review and onto South College Street. Gravity Sewer main also present along South Tryon Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.