



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

| | | | |
|---------------------------|--------------|-----------------------|--------------------------|
| Petition #: | 2013-091 | Review Number: | 1 |
| Petition Reviewer: | Matt Bedford | Date Reviewed: | October 3, 2013 |
| Phone Number: | 704-391-5163 | Email Address: | mbedford@charlottenc.gov |

Comments:

8-inch water main on Marvin Road, and 6-inch water main on Wilkie Drive

8-inch gravity sewer main runs through North side of property. 8" gravity sewer main and 30" sewer force main on Marvin Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.