



**Charlotte Mecklenburg Utility Department**  
**5100 Brookshire Boulevard**  
**Charlotte, NC 28062**  
 Re-Zoning Petition Review

<b>Petition #:</b>	2013-094	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	October 11, 2013
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

<p><b>Comments:</b></p> <p>8-inch and 24-inch water main on Prosperity Church Road. 16-inch water main on Old Ridge Road.</p> <p>8-inch gravity sewer main located to East of Parcels in Review, along Prosperity Church Road.</p>
--

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.