



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2013-096	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	October 11, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

2-inch and 6-in water mains located adjacent to parcels under review. 12-inch water main on Statesville Avenue and 24-inch on Dalton Avenue.

Gravity sewer mains located adjacent to parcels under review and on Statesville Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.