




Charlotte Department of Transportation

Memorandum

Date: November 22, 2013

To: Tammie Keplinger
Charlotte-Mecklenburg Planning Department

From: 
Dennis E. Rorie, PE
Development Services Division

Subject: Rezoning Petition 13-099: Approximately 2.70 acres located on the southeast corner of the intersection at Rama Road and Sardis Road.

CDOT has previously commented on the subject rezoning petition in our memorandum dated October 25, 2013.

Vehicle Trip Generation

This site could generate approximately 143 trips per day as currently zoned. Under the proposed zoning the site could generate approximately 260 trips per day.

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' and two 10' x 70' sight triangles are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. The existing driveway connections to Rama Road and Sardis Road will require driveway permits to be submitted to CDOT and the North Carolina Department of Transportation for review and approval. The exact driveway locations and type/width of the driveways will be determined by CDOT during the driveway permit process. The locations of the driveways shown on the site plan are subject to change in order to align with driveways on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.

Tammie Keplinger
November 22, 2013
Page 2 of 2

5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

If we can be of further assistance, please advise.

cc: S. Correll
Rezoning File