



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-03	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	November 20, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

16-inch water main on Ardrey Kell Road and 12-inch water main on Marvin Road.

Gravity sewer extension will be required to tie in to existing sewer infrastructure. Roughly 1600 feet of sewer extension will be required along Ardrey Kell Road, or roughly 1400 feet of sewer extension along of Marvin Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.