



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-005	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	December 18, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:
6-inch and 16-inch water mains located on Central Avenue, in front of property.

Gravity sewer present in front of property on Central Avenue.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.