



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-013	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	December 18, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

16-inch water main on Providence Road and 12-inch water main on Kuykendall Road.

8-inch gravity sewer main located on Providence road at Northern corner of property.
Also a 8-inch gravity sewer main located roughly 550 feet from property on Kuykendall Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.