



**MECKLENBURG COUNTY**  
Land Use and Environmental Services Agency

January 16, 2014

Ms. Penelope Cothran  
Charlotte-Mecklenburg Planning Commission  
600 East Fourth Street  
Charlotte, North Carolina 28202

**Re: Rezoning Petition 2014-014**

Approximately 1.9 acres located on the north corner at the intersection of Northlake Centre Parkway and Point O'Woods Drive.

Dear Ms. Cothran:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

**Programs with No Comment at this Time**

Water Quality  
Solid Waste  
Groundwater & Wastewater Services  
Storm Water Services

**Recommendations and/or Ordinance Requirement Reminders**

**Air Quality Comments**

Development of this site may require submission of an asbestos Notification of Demolition and Renovation due to possible demolition or relocation of an existing structure or renovation of a load-bearing wall in an existing structure. This notification is required in accordance with the MCAPCO Regulation 2.1110 - Subparagraph (a) - "National Emission Standards for Hazardous Air Pollutants". A letter of notification and the required forms will be mailed directly to the parcel owner.

Please contact the staff members who conducted the reviews if you have any questions. The reviews were conducted by, Megan Green (Megan.Green@mecklenburgcountync.gov) with MCAQ, Dennis Tyndall (Dennis.Tyndall@mecklenburgcountync.gov) with GWS, Joe Hack (Joe.Hack@mecklenburgcountync.gov) with MCSW, Bill Tingle

Page 2

(Bill.Tingle@mecklenburgcountync.gov) with MCSWS, and Rusty Rozzelle  
(Rusty.Rozzelle@mecklenburgcountync.gov) with MCWQ.

Respectfully,

Heidi Pruess, Environmental Policy Administrator  
[Heidi.Pruess@mecklenburgcountync.gov](mailto:Heidi.Pruess@mecklenburgcountync.gov)