



**MECKLENBURG COUNTY**  
Land Use and Environmental Services Agency

January 16, 2014

Ms. Penelope Cothran  
Charlotte-Mecklenburg Planning Commission  
600 East Fourth Street  
Charlotte, North Carolina 28202

**Re: Rezoning Petition 2014-016**

Approximately 2.59 acres located on the west side of Old Concord Road between Suther Road and Circle.

Dear Ms. Cothran:

Representatives of the Air Quality (MCAQ), Groundwater & Wastewater Services (MCGWS), Solid Waste (MCSW), Storm Water Services (MCSWS), and Water Quality (MCWQ) Programs of the Mecklenburg County Land Use and Environmental Services Agency (LUESA) have reviewed the above referenced rezoning petition.

**Programs with No Comment at this Time**

Water Quality  
Solid Waste  
Storm Water Services

**Recommendations and/or Ordinance Requirement Reminders**

**Air Quality**

Development of this site may require submission of an asbestos Notification of Demolition and Renovation due to possible demolition or relocation of an existing structure or renovation of a load-bearing wall in an existing structure. This notification is required in accordance with the MCAQ Regulation 2.1110 - Subparagraph (a) - "National Emission Standards for Hazardous Air Pollutants". A letter of notification and the required forms will be mailed directly to the parcel owner.

**Groundwater & Wastewater Services**

GWS has a record of an existing water supply well located on parcel 049-291-01 within the bounds of the subject project.

GWS recommends that the petitioner identify any water supply wells within the project boundary and either protected the wells from damage by flagging and fencing during site

development or permanently abandon the wells per the Mecklenburg County Groundwater Well Regulations prior to any demolition or grading activity occurring and conduct survey to locate the septic systems. A permit from GWS is required for the well abandonments.

Groundwater & Wastewater Services request the following statements be added to the site plan notes:

The properties shall be inspected for water supply wells. Any water supply wells identified shall be protected from damage by flagging and fencing during site development or permanently abandoned per the Mecklenburg County Groundwater Well Regulations prior to any demolition or grading activity occurring.

Please contact the staff members who conducted the reviews if you have any questions. The reviews were conducted by, Megan Green (Megan.Green@mecklenburgcountync.gov) with MCAQ, Dennis Tyndall (Dennis.Tyndall@mecklenburgcountync.gov) with GWS, Joe Hack (Joe.Hack@mecklenburgcountync.gov) with MCSW, Bill Tingle (Bill.Tingle@mecklenburgcountync.gov) with MCSWS, and Rusty Rozzelle (Rusty.Rozzelle@mecklenburgcountync.gov) with MCWQ.

Respectfully,

Heidi Pruess, Environmental Policy Administrator  
[Heidi.Pruess@mecklenburgcountync.gov](mailto:Heidi.Pruess@mecklenburgcountync.gov)