



# Charlotte Department of Transportation

## Memorandum

---

**Date:** December 23, 2013

**To:** Tammie Keplinger  
Charlotte-Mecklenburg Planning Department

**From:** Michael A. Davis, PE *Mike Davis*  
Development Services Division

**Subject:** Rezoning Petition 14-017: Approximately 0.19 acres located on the south corner at the intersection of South Tryon Street and West Park Avenue.

---

CDOT has completed a review of the subject petition in order to ensure consistency with the Transportation Action Plan (TAP). The TAP seeks to ensure that Charlotte's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users. Based on our review of the petition, we offer the following comments.

### Vehicle Trip Generation

This site could generate approximately 170 trips per day as currently zoned. TOD – M allows for a wide array of land-uses and associated trip generations.

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrances. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. Any proposed driveway connections to South Tryon Street and West Park Avenue will require driveway permits to be submitted to CDOT and the North Carolina Department of Transportation for review and approval. The exact driveway locations and type/width of the driveways will be determined by CDOT during the driveway permit process. Any proposed driveway will be required to align with driveways on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.

Tammie Keplinger  
December 23, 2013  
Page 2 of 2

5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

If we can be of further assistance, please advise.

C. Leonard

cc: S. Correll  
Rezoning File