



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-018	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	December 18, 2013
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

12-inch and 24-inch water mains on Prosperity Church Road.

8-inch gravity sewer mains located roughly 600 feet from property on Prosperity Church Road. 8-inch gravity sewer main roughly 300 feet from property on Prosperity Paint Lane. Gravity sewer extension will be required to tie in to existing sewer infrastructure.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.