



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-028	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	February 13, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

6-inch water mains on Abbey Place and Hedgemore Drive.

8-inch gravity sewer mains on along Hedgemore Drive and Abbey Place. Also present is an 8-inch and a 48-inch gravity sewer main that runs through property under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.