



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-031	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	February 13, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

12-inch water main on Youngblood Road and Grand Palisades Parkway. 8-inch water main on Shelburne Farms Drive.

8-inch sewer force main to the north of property on Youngblood Road. 8-inch gravity sewer connection to the sough of parcel on Grand Palisades Parkway.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.