



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-033	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	March 24, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch water main along Rea Road and the 8-inch water Main on Piper Station Drive.

Sewer Service is provided by the existing 8-inch gravity sewer main located along Piper Station Drive and through parcel under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.