



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

| | | | |
|---------------------------|--------------|-----------------------|--------------------------|
| Petition #: | 2014-035 | Review Number: | 1 |
| Petition Reviewer: | Matt Bedford | Date Reviewed: | March 24, 2014 |
| Phone Number: | 704-391-5163 | Email Address: | mbedford@charlottenc.gov |

Comments:

Access to the CMUD Water System is available via the existing 12-inch water mains along David Taylor Drive and Claude Freeman Drive. Parcel under review is located at the corner of a Pressure Boundary Zone. Customer should work closely with CMUD to ensure connection to the correct portion of CMUD's water system.

Sewer Service is provided by the existing 8-inch gravity sewer mains located along Claude Freeman Drive and David Taylor Drive.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.