



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

Petition #:	2014-042	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	April 16, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 16-inch water main along South Tryon Street and the 8-inch water main along Moss Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer main located to the west of property under review along South Tryon Street. Estimated distance from parcel to the sanitary sewer connection is 300 feet.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.