



**Charlotte Mecklenburg Utility Department**  
5100 Brookshire Boulevard  
Charlotte, NC 28062  
Re-Zoning Petition Review

<b>Petition #:</b>	2014-043	<b>Review Number:</b>	1
<b>Petition Reviewer:</b>	Matt Bedford	<b>Date Reviewed:</b>	April 16, 2014
<b>Phone Number:</b>	704-391-5163	<b>Email Address:</b>	mbedford@charlottenc.gov

**Comments:**

Access to the CMUD Water System is available via the existing 24-inch and 12-inch water mains along Prosperity Church Road.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer main located to the outhwest of property under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.