



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-050	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	April 16, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 12-inch and 30-inch water mains along Carmel Road and the existing 8-inch water main along Colony Road.

Access to the CMUD Sewer Service is available from two locations. On the west side of parcels under review, access is available from the existing 8-inch gravity sewer mains located along Carmel Road at the intersection of Knapdale Lane. On the East Side of the parcels, access is available from the existing 8-inch gravity sewer main located on the oppositsde side of Colony Road from the parcels under review.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.