



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-052	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	April 16, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD Water System is available via the existing 24-inch and 12-inch water mains along Reagan Drive and the existing 6-inch water main along North Graham Street.

Access to the CMUD Sewer Service is available from the existing 8-inch gravity sewer main located along North Graham Street and the existing 8-inch gravity sewer which starts at parcel under review and runs along Pebble Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.