



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
Re-Zoning Petition Review

| | | | |
|---------------------------|--------------|-----------------------|--------------------------|
| Petition #: | 2014-055 | Review Number: | 1 |
| Petition Reviewer: | Matt Bedford | Date Reviewed: | May 10, 2014 |
| Phone Number: | 704-391-5163 | Email Address: | mbedford@charlottenc.gov |

Comments:

Access to the CMUD Water System is available via the existing 6-inch water main on North Davidson Road.

Access to the CMUD Sewer Service is available via the existing 8-inch gravity sewer main located along North Davidson Street.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.