



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-063	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	May 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

<p>Comments:</p> <p>Access to the CMUD water system is available via the existing 6-inch water mains along Marshall Place and Atherton Street.</p> <p>Access to the CMUD sewer system is available via the existing gravity sewer mains along Marshall Place and Atherton Street.</p>
--

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.