



Charlotte Mecklenburg Utility Department
5100 Brookshire Boulevard
Charlotte, NC 28062
 Re-Zoning Petition Review

Petition #:	2014-067	Review Number:	1
Petition Reviewer:	Matt Bedford	Date Reviewed:	May 10, 2014
Phone Number:	704-391-5163	Email Address:	mbedford@charlottenc.gov

Comments:

Access to the CMUD water system is available via the existing 16-inch and 8-inch water mains along Shamrock Drive, and the existing 12-inch water main on Eastway Drive. and.

Access to the CMUD sewer system is available via the existing 8-inch and 10-inch gravity sewer main that runs through middle of parcel #101-021-01, just to the east of the divining line of what is to be rezoned. To the Northwest of the parcels under review, access is available via existing 10-inch, 15-inch, and 21-inch gravity sewer mains located along Briar Creek running through these parcels, as well as along Eastway Drive and Shamrock Road.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. It does not imply available capacity in lines, pump stations, or treatment facilities.